

Electrical Safety Program

Appendix H-Department of Environmental Health & Safety Audit Checklist

Yes	No	Field Corrected (EHS Initials)	Item:
			Are annual field audits performed and documented by a supervisor for all workers?
			Do all qualified electrical workers have Cat III, 600 Volt rated meters (ANSI S82.82)?
			Do all qualified electrical workers have AF PPE Category 2 PPE (Arc rated clothing, face shields, etc.)?
			Do all workers have arc rated shirts and pants rated at a minimum of 8 cal/cm ² ?
			Do all workers have arc rated face shields?
			Do all workers have balaclavas rated a minimum of 8 cal/cm ² ?
			Do all workers have safety glasses?
			Do all workers have hearing protection?
			Do all workers have insulated gloves tested in the last 6 months (gloves stamped)?
			Do all workers have leather protectors to wear over insulated gloves?
			Do all workers have beekeeper style hoods rated at a minimum of 40 cal/cm ² ?
			Do all workers have bibs/coveralls, and jackets rated at a minimum of 40 cal/cm ² ?
			Do all workers have insulated tools (ASTM F 1505)?
			Are energized electrical work permits available upon request?
			Do all workers receive classroom retraining every 3 years?

EHS

Maintenance Supervisor